



8 Gang Flow Distribution Hub



With the emphasis on flexibility and ease of installation, many building design projects are now focusing on products and services that can adapt to changing legislation, energy efficiency and the ever changing needs of the client. The Flow Distribution Hub has been designed to help contractors create more complex lighting installations quickly, easily and safely.

8 Gang Flow Distribution Hub

Product Range


8 Gang Flow Distribution Hub

CT1008

250V~ 20A 8 Way Distribution Box



Product Dimensional Drawings (mm)



V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362

Website: www.scolmore.com



8 Gang Flow Distribution Hub

Technical Specification

8 Gang Flow Distribution Hub

Material Composition

Front Plate, Back Box, Mounting Plate: Mild Steel

Male & Female Connectors: Nylon PA66

Terminals: HPb59-1 (CU 59%) Silver Plated

Terminal Screws: Steel and Yellow Passivated

Dust Covers Provided: Polycarbonate

Voltage

250V~ 50Hz

Current Rating

20A Max

Compatible Connectors

CT102C - 3 Pin Connector (Screw Cable Clamps)

CT103C - 3 Pin Connector (Fast-fit Cable Clamps)

CT202C - 4 Pin Connector (Screw Cable Clamps)

CT203C - 4 Pin Connector (Fast-fit Cable Clamps)

CT1300 - 3 Pin Switch Adapter

CT300 - 4 Pin (1 In 3 Out) HUB Junction Box

CT350 - 4 Pin (1 In 2 Out) Splitter

Input / Output

1 Male Input (Supply) to receive Female Connector

1 Female Output to receive Male Connector

8 Female Outputs to receive 8 Male Connectors

Switch Configurations

2 Way 8 Gang Configuration

1 Way 8 Gang Configuration

Warranty

10 Years

IP Rating

IP20

Operational Temperature

-5° to +40°C

Standards

KEMA-KEUR

BS 5733 : 2010 + A1 : 2014

BS 8488 : 2009 + A1 : 2010

IEC EN 61535 : 2009 + A1: 2013 + C1: 2014

Errors & Omissions excluded. Specification is subject to change without notice. Pre-Fabricated wiring systems manufactured to BS 8488 by other manufacturers may not be compatible or safely inter-connectable with this system. Any dangerous compatibility between different manufacturers installation coupler systems is not automatically prevented by compliance with IEC 61535.

V1.0

Scolmore International Ltd, 1 Scolmore Park, Landsberg, Lichfield Road Ind. Estate, Tamworth, Staffordshire, B79 7XB

Telephone: 01827 63454

E-mail: sales@scolmore.com, technical@scolmore.com

Facsimile: 01827 63362

Website: www.scolmore.com



Scolmore International Ltd

1 Scolmore Park: Landsberg
Lichfield Road Industrial Estate
Tamworth, Staffordshire B79 7XB

t: 01827 63454

f: 01827 63362

e: sales@scolmore.com

w: www.scolmore.com

DECLARATION OF CONFORMITY

1. *Issuer Name* Scolmore International Limited
2. *Issuer Address* 1 Scolmore Park, Landsberg,
Lichfield Road Industrial Estate,
Tamworth, Staffordshire, B79 7XB
3. *Object(s) of Declaration* The Flow Range
 - a. *Group* Flow Distribution Box
 - b. *Models No.* CT1008
4. *The object of the declaration described above is in conformity with the requirements of the following Certification Mark:*

KEMA-KEUR

5. *All products contained within the aforementioned comply with the relevant standards and requirements listed below.*

BS 5733 : 2010 + A1 : 2014

BS 8488 : 2009 +A1 : 2010

IEC EN 61535 : 2009 + A1: 2013 + C1: 2014

6. *I hereby declare that the equipment named above has been designed to comply with the relevant sections of the above referenced specifications. The unit complies with all applicable Essential Requirements of the Directives.*

In conjunction with the above all manufacture and process controls are in accordance with ISO 9001:2008

Signed, for and on behalf of: Scolmore International Limited

Steven Bettson BSc - Senior Technical Support Engineer

CE 14